

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 35

Date: 12/03/26

It is certified that an inspection team headed by Mr. Ravikant Audichya

(Name of Officers with designation) from Health officer zone 01.

PHED inspected the CAMPION SCHOOL, BHOURI BHOPAL (M.P.) (Name & Address of the school) on

05.03.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no.

46 dated 12.03.2026 of Water testing Laboratory
Sanit Hindoaram Nagar (Bairagach)

(PHED Lab) certified that the CAMPION SCHOOL, BHOURI BHOPAL (M.P.) (name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State/ U.T. Govt.

This certificate is valid till 09.03.2027.

Signature with Seal -

Name :

Designation :

Name & Address of the Office / Department :

रविकान्त औदिक्य
स्वास्थ्य अधिकारी
जोन नं-01
नगर निगम भोपाल

To,
Campion School, Bhouri Bhopal
Tehsil Huzur Dist. - Bhopal
Near Chirayu Medical College
(Name & Address of the Institution)

[Signature]
MANAGER
CAMPION SCHOOL
Bhouri PO, Tehsil-Huzur,
Dist. Bhopal,
Madhya Pradesh-462030

[Signature]
PRINCIPAL
CAMPION SCHOOL
BHOURI, BHOPAL (M.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.



Water Testing Laboratory Sant Hirdaram Nagar (Bairagarh)
Nagar Nigam, Bhopal



Test Report

Nature of Sample :- Drinking Water Sample / others	Sampled / Not Sampled by Lab	Unique Identification No.	
Sender's Name and Address To. Campion School Bhouri Bhopal Tehsil Huzur Distic Bhopal Near Chirayu Medical College	Sender's letter no.	Sender's letter Date	
	WTL Re. No.	WTL Re. No.	
	Date of analysis Started	Date of analysis completed	12/03/2026
	Quantity of Sample		

Sample Details

No.	Particulars of Samples
1	Sample From – Tube well Water Campion School Bhouri Bhopal
2	Sample From – RO Water Campion School Bhouri Bhopal
3	
4	
5	

RESULTS

No	Characteristics/Unit	Test Methods	BIS – 10500:2012 Reaffirmed in Sep 2022		Results				
			Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5					
1	Colour in cu	IS 3025 Part 4:2021	5	15	NIL	NIL	-	-	-
2	Teste	IS 3025 Part 8:1984	Agreeable	Agreeable	-	Agreeable	-	-	-
3	Odour	IS 3025 Part 5:2018	Agreeable	Agreeable	-	Agreeable	-	-	-
4	P ^H Value at 25°C	IS 3025 Part 11:1983	6.5 to 8.5	6.5 to 8.5	7.30	7.05	-	-	-
5	Chloride as Cl mg/l	IS 3025 Part 32:1988	250	1000	75	18	-	-	-
6	Total Alkalinity as CaCO ₃ mg/l	IS 3025 Part 23:1986	200	600	240	35	-	-	-
7	Calcium as Ca ⁺⁺ mg/l	IS 3025 Part 40:1991	75	200	79.8	12.6	-	-	-
8	Magnesium as Mg ⁺⁺ mg/l	APHA 23 rd edition, 3500 Mg-	30	100	66.8	9.96	-	-	-
9	Turbidity in NTU	IS 3025 Part 10:2023	1.0	5.0	0.56	0.15	-	-	-
10	Total Hardness as CaCO ₃ mg/l	IS 3025 Part 21:2009	200	600	370	56	-	-	-
11	TDS By meter mg/l	IS 3025 Part 11:1984	500	2000	410	100	-	-	-
12	Total coliform per 100 ml	APHA 23 rd edition, 9211 B	NIL for treated water and water in Distribution system		NIL	NIL	-	-	-
13	E. Coli or (TTC) per 100 ml	IS 1622			NIL	NIL	-	-	-

- This Report Should Not be Produced Partly or full without Approval of Signatory authority for Legal Purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned Under "acceptable" render the water suitable. But still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
- The Results refer only to tested samples and parameters tested.
- Samples will be stored for a period of 5 days from the date of issue of report.
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Assistant chemist

MANAGER
CAMPION SCHOOL
Bhouri PO, Tehsil-Huzur,
Dist. Bhopal,
Madhya Pradesh-471003

LAB INCHARGE

Issue No. 46 /WTL/NN/BPL/2024 issue Date 12/03/2026

PRINCIPAL
CAMPION SCHOOL
BHOURI, BHOVAL (M.P.)



Water Testing Laboratory Sant Hirdaram Nagar (Bairagarh)
Nagar Nigam, Bhopal



Test Report

Nature of Sample :- Drinking Water Sample / others	Sampled / Not Sampled by Lab	Unique Identification No.	
Sender's Name and Address To. Campion School Bhouri Bhopal Tehsil Huzur Distic Bhopal Near Chirayu Medical College	Sender's letter no.	Sender's letter Date	
	WTL Re. No.	WTL Re. No.	
	Date of analysis Started	Date of analysis completed	12/03/2026
	Quantity of Sample		

Sample Details

No.	Particulars of Samples
1	Sample From – RO Water Campion School Bhouri Bhopal
2	
3	
4	
5	

RESULTS

No	Characteristics/Unit	Test Methods	BIS – 10500:2012 Reaffirmed in Sep 2022		Results				
			Desirable Limit	Permissible Limit	1	2	3	4	5
	2	3	4	5					
1	Colour in cu	IS 3025 Part 4:2021	5	15	NIL	-	-	-	-
2	Taste	IS 3025 Part 8:1984	Agreeable	Agreeable	Agreeable	-	-	-	-
3	Odour	IS 3025 Part 5:2018	Agreeable	Agreeable	Agreeable	-	-	-	-
4	pH Value at 25°C	IS 3025 Part 11:1983	6.5 to 8.5	6.5 to 8.5	7.05	-	-	-	-
5	Chloride as Cl mg/l	IS 3025 Part 32:1988	250	1000	18	-	-	-	-
6	Total Alkalinity as CaCO ₃ mg/l	IS 3025 Part 23:1986	200	600	35	-	-	-	-
7	Calcium as Ca ⁺⁺ mg/l	IS 3025 Part 40:1991	75	200	12.6	-	-	-	-
8	Magnesium as Mg ⁺⁺ mg/l	APHA 23 rd edition, 3500 Mg-	30	100	9.96	-	-	-	-
9	Turbidity in NTU	IS 3025 Part 10:2023	1.0	5.0	0.15	-	-	-	-
10	Total Hardness as CaCO ₃ mg/l	IS 3025 Part 21:2009	200	600	56	-	-	-	-
11	TDS By meter mg/l	IS 3025 Part 11:1984	500	2000	100	-	-	-	-
12	Total coliform per 100 ml	APHA 23 rd edition, 9211 B	NIL for treated water and water in Distribution system		NIL	-	-	-	-
13	E. Coli or (TTC) per 100 ml	IS 1622			NIL	-	-	-	-

- This Report Should Not be Produced Partly or full without Approval of Signatory authority for Legal Purposes.
- it is recommended that acceptable limit is to be implemented. Values in excess of those mentioned Under "acceptable" render the water suitable. But still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
- The Results refer only to tested samples and parameters tested.
- Samples will be stored for a period of 5 days from the date of issue of report.
- This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

[Signature]

MANAGER
CAMPION SCHOOL
Bhouri PO, Tehsil-Huzur,
Dist. Bhopal,
Madhya Pradesh-462030

[Signature]
Assistant chemist

LAB INCHARGE

[Signature]
PRINCIPAL
CAMPION SCHOOL
BHOURI, BHOPAL (M.P.)

Issue No. 46 /WTL/NN/BPL/2024 issue Date 12/03/2026